



Product Service

CERTIFICATE

No. Z2 068988 0124 Rev. 01

Holder of Certificate: **Jetion Solar (China) Co., Ltd.**

No. 1011, Zhencheng Rd.,
Shengang Industrial District
214443 Jiangyin
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062319003-01

Valid until: 2029-06-26

Date, 2024-07-02

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



CERTIFICATE

No. Z2 068988 0124 Rev. 01

Model(s):

JTxxxSLk(B), xxx=685 to 720, in steps of 5
 JTxxxSlk(B), xxx=620 to 650, in steps of 5
 JTxxxSZk(B), xxx=570 to 600, in steps of 5
 JTxxxSJk(B), xxx=570 to 590, in steps of 5
 JTxxxSNk(B), xxx=505 to 525, in steps of 5
 JTxxxSYk(B), xxx=420 to 440, in steps of 5
 JTxxxSRt(B), xxx=610 to 640, in steps of 5
 JTxxxSSt(B), xxx=560 to 590, in steps of 5
 JTxxxSLt(B), xxx=510 to 530, in steps of 5
 JTxxxSlT(B), xxx=460 to 490, in steps of 5
 JTxxxSJt(B), xxx=415 to 440, in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou Hua Yang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2023
 IEC 61730-2:2023